

DVGW-Baumusterprüfzertifikat

DVGW type examination certificate

DW-9191BN0076

Registriernummer
registration number

Anwendungsbereich <i>field of application</i>	Produkte der Wasserversorgung <i>products of water supply</i>
Zertifikatinhaber <i>owner of certificate</i>	BWT Austria GmbH Walter-Simmer-Str. 4, A-5310 Mondsee
Vertreiber <i>distributor</i>	BWT Austria GmbH Walter-Simmer-Str. 4, A-5310 Mondsee
Produktart <i>product category</i>	drinking water treatment devices and systems: water conditioning device for the diminution of scaling (9191)
Produktbezeichnung <i>product description</i>	water conditioning devices for the diminution of scaling
Modell <i>model</i>	AQA total Energy 11200
Prüfberichte <i>test reports</i>	mechanical test: from 22.03.2010 (TZW) mechanical test: CA 021/06 from 06.12.2007 (TZW) KTW testing: KA 103A/05 from 03.05.2005 (TZW) hygienic testing: 073A06_2 from 13.12.2006 (TZW) KTW testing: KA 352/09 from 23.11.2009 (TZW) hygienic testing: MO 047/08 from 04.07.2008 (TZW) KTW testing: C-164804-08-Ko/st from 24.06.2008 (WHY)
Prüfgrundlagen <i>basis of type examination</i>	DVGW W 512 (01.09.1996) DVGW W 510 (01.04.2004) BGA KTW (07.01.1977) DVGW W 270 (01.11.2007)
Ablaufdatum / AZ <i>date of expiry / file no.</i>	15.03.2015 / 10-0004-WNV

06.05.2010 GI A-1/2

Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle
date, issued by, sheet, head of certification body

DVGW CERT GmbH - von der Deutschen Akkreditierungsstelle Technik (DATech) in der TGA GmbH akkreditiert für die Konformitätsbewertung von Produkten der Gas- und Wasserversorgung

DVGW CERT GmbH - accredited by Deutsche Akkreditierungsstelle Technik (DATech) in the TGA GmbH for conformity assessment of products of gas and water supply



DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888
Telefax: +49 228 91 88-993
eMail: info@dvgw-cert.com

DAT-ZE-009/96-02

Typ <i>type</i>	Technische Daten <i>technical data</i>	Bemerkungen <i>remarks</i>
AQA total Energy 11200	pressure rating: PN 10 nominal diameter: DN 50 flow capacity: 11,2 m³/h	

zertifizierte Bauteile / Werkstoffe
certified components

Registr.-Nr. <i>registration no.</i>	Bauteil (Produktart) <i>component</i>	Modell/Typ <i>model/type</i>	Hersteller <i>manufacturer</i>
NW-6312AS2269	plug-in non-return valve	OF, OD, OV, NF, NV, CV, SYR/NV 50, NV 50-EPDM, OV 50, NF 50	NEOPERL GmbH

Verwendungshinweise / Bemerkungen
hints of utilization / remarks

With the test reports 073A06_2 date: 13.02.2006 (TZW) and W-158311k-07-SI date: 28.01.2008 (WHY) it is proven, that the requirements according the standard DVGW W270 (01.11.2007) appendix A.1.1: "Material for the standard application in contact with potable water" are fulfilled.

With the test reports MO 365A/07 date: 30.11.2007 (TZW) for the range of application D1 and D2, MO 356A/07 date: 17.10.2007 (TZW) for the range of application D1 and D2, and MO 352A/07 date: 12.10.2007 (TZW) for the range of application D2 it is proven, that the requirements according the standard DVGW W270 (01.11.2007) appendix A.1.3: "Test reports acc. DVGW W 270 (01.11.1999) for the range of application large-scale seals (D1) and small-scale seals (D2)" are fulfilled.